



FIRE & RISK
★★ALLIANCE★★

BlueWave Energy

Worthington Battery Energy Storage System
Fire, Explosion, Plume & Soil

James Caulfield

- **QUALIFICATIONS:**
- Active New Jersey Firefighter
- 22 years of Law Enforcement and Fire Service experience
- Retired Police Officer
- National Tactical Officer Association operator
- Monmouth County Police Academy Instructor
- Threat, Risk and Vulnerability assessment coordinator
- Incident Command System 100, 200, 300, 700 and 800
- FBI Crisis management
- Sports and special events incident management
- Field training officer
- TTT Civilian response to active shooter
- Emergency response team operator
- Community policing / Crisis management



Agenda



BATTERY ENERGY
STORAGE



BATTERY SYSTEM
FAILURES



FIRE



EXPLOSION



PLUME



SOIL




Battery Energy Storage

Concept & Overview






BATTERY ENERGY STORAGE SYSTEM CONCEPT



Battery System Anatomy




Site Layout





Battery System Failures

Cause & Correction



Moss Landing Incident

Open Design

Single Room / No Fire Breaks


Installed 2020

**Before Codes / Standard were
Established**





Moss Landing Battery Site 762' x 75'



Moss Landing Soil Samples: Executive Summary



Executive Summary

Terraphase Engineering Inc. (Terraphase) has prepared this *Soil Sampling Report*, on behalf of Vistra Corp., to present the results of surface and near-surface soil sampling conducted in the vicinity of the Moss Landing Power Plant at 7301 Highway 1, Moss Landing, California (MLPP; the Site; Figure 1). The sampling program was requested and approved by the County of Monterey Health Department's Environmental Health Bureau (EHB) in response to the January 16, 2025, lithium-ion battery fire which occurred at the Moss Landing 300 MW battery storage facility.

On May 8, 18, and 22, and June 20, 2025, Terraphase collected surface and shallow subsurface soil samples from 27 pre-determined locations within a 10-mile radius of ML300. The 108 primary and 10 duplicate soil samples were submitted for analysis of metals associated with the batteries that were damaged in the ML300 fire (aluminum, cobalt, copper, lithium, manganese, and nickel), as well as lead, pH, and moisture content. Sixteen soil samples from four selected boring locations were additionally analyzed for polycyclic aromatic hydrocarbons, and dioxins and furans.

Data generated during the investigation were compared to EHB-approved screening levels, which were based on residential health protective standards established by the Department of Toxic Substances Control and/or United States Environmental Protection Agency. There were no detections of aluminum, copper, lithium, nickel, polycyclic aromatic hydrocarbons, or dioxins and furans above the EHB-approved screening criteria.

There were no exceedances of residential screening levels of the other metals (cobalt, lead, and/or manganese) in 110 out of 118 soil samples. The few isolated detections of cobalt, lead, and/or manganese in 8 out of 118 soil samples are not indicative of fire-related impacts, because of one or more of the following reasons: (a) the exceedances were observed in the subsurface but not the surface soil sample; (b) the exceedance was only for lead, which is not a key metal associated with the lithium-ion batteries involved in the ML300 fire; (c) although an exceedance was observed in the original analysis of a shallow soil sample, the result from the reanalysis of this sample was below the screening level; and/or (d) the concentrations were within the range of naturally occurring metals concentrations observed in soils.

Based on the data generated from this investigation, Terraphase has concluded that no further soil investigation is warranted.

EPA Air Monitoring – Moss Landing



EPA Completes Air Monitoring Near Moss Landing Vistra Battery Fire

Emergency Response -- Monitoring by the state and Vistra will continue to watch for any risks to public health


January 20, 2025

Contact Information

Mikayla Rumph (rumph.mikayla@epa.gov)
(213) 317-5259

MONTEREY—On January 20, the U.S. Environmental Protection Agency (EPA) concluded supplemental air monitoring in the vicinity of the Vistra Energy battery power storage facility fire in Moss Landing, CA. Results for hydrogen fluoride and particulate matter showed no risk to public health throughout the incident, and smoke from the facility has greatly diminished. The EPA demobilized air monitoring operations after consultation with the Monterey County Incident Command for the Vistra fire.

EPA began monitoring for hydrogen fluoride, a highly toxic gas produced by lithium-ion battery fires, and for particulate matter after the fire began on January 16. The request for air monitoring came from Monterey County. As part of the multi-agency emergency response, EPA installed a total



Water Intrusion 2-NYS 1-Idaho



Jul 07, 2023, 6:45am • Updated on Jul 07, 2023

By: **News 12 Staff**






WLL 100,000 LB

TESLA

IP66 Enclosure Rating
1,600 GPM for 20 Minutes



Community Exposures



Distance To Exposures



- **The nearest residence is the landowner's property, approximately 535' from the edge of equipment pad where the batteries will be.**
- **The nearest abutting residence is approximately 775' from the edge of the equipment pad.**



Fires

Response Philosophy



Extinguishing Fire: Life & Property



Intervention: Containment



ABC 10 NEWS | SAN DIEGO



Cell Failure

Venting & Thermal Runaway





Overcoming Internal Pressure



90% State of Charge



< 30 % State of Charge





Explosion

Arizona 2019 - APS McMicken



EXPLOSION RISK – LESSONS LEARNED



Explosion Control Systems



NFPA
68

Standard on
Explosion Protection by

NFPA®
69

Standard on
Explosion Prevention
Systems

2024

NFPA 68: Deflagration Vents




NFPA 69 FLAMMABLE GAS PURGE





Plume



Escondido Battery Fire



Escondido Battery Fire



EVACUATION MAP (RED AREA: EVACUATIONS; PURPLE AREA: SHELTER IN PLACE):





Fire Department Air Monitoring

Active Air Monitoring	% Detected	IDLH
Carbon Monoxide	0	1,200 PPM
Carbon Dioxide	0	40,000 PPM
Hydrogen Fluoride	0	30 PPM
Hydrogen	0	
Hydrogen Sulfide	0	100 PPM
Hydrogen Cyanide	2 PPM	50 PPM
Oxygen	20.8	
LEL	0	

Post Fire Water & Plume Reports



Home About ▾ Our Work ▾ Resources ▾ News & Events ▾ Membership ▾

Oct 2, 2024 11:23:38 AM

Air and Water Quality Data from Escondido Fire Show Minimal Contamination


CESA

Share: [f](#) [in](#) [t](#) [p](#) [e](#)

Energy storage is essential to decarbonize electricity supplies, but some communities have expressed concern about the safety implications of proposed energy storage facilities. While the energy storage industry strives to minimize the likelihood of BESS incidents, the findings of two recent reports add further evidence demonstrating that fires at energy storage facilities produce emissions that are comparable to other structure fires and pose minimal risk for public health and the environment.

On September 19, two weeks after the September 5 fire that occurred at an energy storage facility in Escondido, the City of Escondido released two reports on the findings of the air and water quality monitoring that took place during the incident. The air quality data came from 11 different locations monitored by San Diego County HAZMAT and 17 locations monitored by Haley & Aldrich, Inc., an engineering and environmental compliance firm under contract with SDG&E, the operator of the facility. The stations were located approximately 100 feet to as far as 4,000 feet from the affected container and monitored six toxic gases. The equipment only detected the presence of two of the monitored gases, carbon monoxide and hydrogen cyanide, but readings for both gases were well below acceptable limits. The report concludes that "... only normal products combustion [sic] of a structure fire were detected and at levels considered by NIOSH and OSHA to be well below exposure thresholds."

Samples of runoff water were assessed for the presence of 17 toxic metals. The analysis detected some level of six of the 17 metals, but the report notes that the concentrations were well below EPA drinking water standards and the runoff "poses minimal risk to both human health and the environment."



Plume Gas Results & Action Thresholds



Gas		CDC IDLH Thresholds	Actual %
Carbon Monoxide	CO	1,200 PPM	145,960 PPM
Carbon Dioxide	CO ₂	40,000 PPM	269,250 PPM
Hydrogen	H ₂	N/A	
Methane	CH ₄	N/A	
Hydrogen Chloride	HCL	50 PPM	
Hydrogen Cyanide	HCN	50 PPM	
Hydrogen Fluoride	HF	30 PPM	





Distance & Dissipation




Plume Behavior

Natural Gas - Propane



Energy Storage Fire vs. Residential Fire






Energy Storage Fire vs. Commercial Fire





Soil

NextEra, East Hampton, NY
Gateway, Otay Mesa, CA



East Hampton BESS – 24 Hour Deluge



Fire Shuts Down East Hampton Energy Storage Batteries



GOVERNOR KATHY HOCHUL

PRESSROOM

SCHEDULE

EXECUTIVE ORDERS

LEGISLATION

ABOUT

CONTACT


◆ Government ◆ Public Safety

DECEMBER 21, 2023 | Albany, NY

Governor Hochul Announces Release of Initial Findings From Inter-Agency Fire Safety Working Group on Emergency Response

Available Analyses Find No Reported Injuries, No Harmful Levels of Toxins Detected at Sites of Battery Storage Fires

Chaumont Battery Fire – Water Applied



New York State Findings



The data assembled and analyzed by the Working Group includes:

- An air monitoring report from the OFPC, and soil and water sampling data received from DEC from the Chaumont site.
- On-site air monitoring results collected from the Warwick sites and relayed to the Working Group by local officials.
- On-site **soil sampling results from the East Hampton site** relayed to the Working Group by a project developer.
- An independent **third-party** site inspection report consisting of **air monitoring and surface sampling** at school buildings in the vicinity of the June 27, 2023, fire at the Warwick site.

Based on the information available to date, there is no evidence of significant off-site migration of contaminants associated with the fires.



Gateway BESS Fire – 6 Million Gallons of Water



Thank You

Questions

James Caulfield
Senior Fire Protection Consultant
jcaulfield@fireriskalliance.com
732 598-6342



FIRE & RISK
ALLIANCE ★ ★